

Brakes Plus
1201 Lonnie Abbott Blvd.
Ada, OK 74820

Bid Clarification:

1.

At the base of stripping operations and prior to the placement of structural fill, we recommend the top 8 inches of the exposed subgrade soils be scarified, moisture conditioned, and recompacted in accordance with **Section 6.2** of this report. In addition, Olsson should observe the base of foundation excavations to confirm both the native and existing fill are consistent with the materials encountered during our exploration and are suitable of providing the foundation support. If soft soils or deleterious materials are encountered, these materials should be removed and replaced with compacted structural fill.

2. Provide unit costs for cut/haul and import fill.