

EOC Northport, AL TWO BUILDINGS

1803 27th St

Northport, AL 35476

Bid Clarification:

- 1. Top 12” of existing soil will need to be scarified and moisture conditioned according to the Geotech report prior to placing any fill.**
- 2. Provide unit pricing for cut/haul and import fill**