

**EOC Kingsland, GA
1125 Boone St
Kingsland, GA 31548**

Bid Clarification:

- 1. Water tap and meter is shown to be 1-1/2", bid should include a 1" tap and meter.**
- 2. HVAC split system is shown to be a gas fired furnace, this is being revised to an electric heat pump, omit the gas supply and vent and provide a dedicated circuit for the air handler.**
- 3. Water table is approximately 2', base bid to include dewatering/wellpoints as required for construction of the pit and all utilities.**
- 4. Provide unit pricing for cut/haul and import fill.**