

Express Oil Change Panama City, FL

2611 Thomas Dr.

Panama City, FL 32408

Bid Clarification:

1. Geotech report calls for surcharging the building pad 5' above FFE. 1-2' will need to be added to establish FFE and then we can excavate the pond material to utilize as surcharging material.
2. Provide dewatering as required for pit and utility installation.
3. Provide unit pricing for cut/haul and import fill.