

Brakes Plus S. Norman, OK

3301 Classen Blvd

Norman, OK 73071

Bid Clarification:

1. Floor slabs should be supported by a minimum of 12 inches of low-plasticity structural fill. This structural fill thickness can be achieved through a combination of over-excavation and recompaction of site soils or structural fill placed to raise site grades and should extend 5 feet beyond the building perimeter
2. Provide unit costs for cut/haul and import fill.